

# Supplement

Manual Title: PQ400 Instructions  
Part Number: 4954885 Supplement Issue: **2**  
Print Date: October 2018 Issue Date: 7/19  
Revision/Date: 1, 2/19 Page Count: 1

---

---

This supplement contains information necessary to ensure the accuracy of the above manual.



Autorisierter Distributor

## Change #1, 691

On the 3<sup>rd</sup> page, replace the 6<sup>th</sup> bullet with:

- **Use a certified circuit breaker marked as the disconnecting device in an easily reached location suitable for the wire gauge used for the voltage inputs to the Product.**

On the 13<sup>th</sup> page, under **Environment**, replace the Humidity with:

Humidity.....10 % to 90 % (non-condensing) in dependency of temperature according to IEC 60721-3-3

Class 3K6 (modified):

-25 °C to 35 °C: 10 % to 90 %,

50°C: max. 35 %,

60°C: max. 23 %

On the 14<sup>th</sup> page, under **Voltage**, replace the Wire gauge with:

Wire gauge..... solid/flexible: 0.25 mm<sup>2</sup> to 1.5 mm<sup>2</sup> (AWG 24 to AWG 16), rated 65 °C min

## Change #2, 730

On the 6<sup>th</sup> page, under **Before you Start**, replace ❷ with:

- ❷ Punch/Die 115.42 mm (4.54 in), for example Greenlee 742BB

On the 7<sup>th</sup> page, under **Site Preparation**, replace step 3 with:

3. Use the Punch/Die with electro-hydraulic hole punch to make the 115.42 mm (4.54 in) hole.

### Autorisierter Distributor

TVW Meßtechnik GmbH  
Sammelweg 31  
32257 Bünde  
Fon: 05223 / 9277 - 0  
Fax: 05223 / 9277 - 40  
info@twwbuende.de  
www.twwbuende.de

